

ELMIRA WATER BOARD

Elmira, New York

Bids for Estimated 2010 Requirements for:

SPECIFICATIONS

COPPER COILS & COPPER COMPRESSION CURB STOPS

will be received by the Elmira Water Board at its office at 261 West Water Street, Elmira, New York 14901 until 10:00 A.M. on Wednesday, December 09, 2009. At this time the bids will be publicly opened and read.

The copper coils shall be 3/4" diameter, type K soft copper in coils of 100' and shall be in conformance with ANSI/NSF-61-25XN and ASTM B-88.

The copper compression curb stops shall be 3/4" Ford part #B44-333-Q (or equal), ball valve type with quick joint ends.

The copper coils and copper compression curb stops will be ordered as one shipment not to exceed 30 days from award confirmation date, and are to be delivered to the Elmira Water Board Maintenance Shop at 760 Bonview Street, Elmira, New York.

Bids shall be quoted on the below quotation form. Bid price should include freight delivered to the Elmira Water Board's Maintenance Shop yard at 760 Bonview Street, Elmira, New York.

Bids must be in sealed envelopes and the quoted material designated on the outside of the envelope. Standard Non-Collusive Bidding Certificate, Waiver of Immunity and Certification of Bidder regarding Equal Employment Opportunity must be signed and submitted with the bid.

The Elmira Water Board reserves the right to waive any informalities and to reject any or all bids and to re-advertise for new bids at its discretion.

BIDDER NAME: _____

Phone: _____ Fax: _____

QUOTATION FORM

<u># Of Units</u>	<u>Size</u>	<u>Cost/Unit</u>	<u>Extended Total</u>
3,000'/100' coils (per feet)	3/4"	_____	_____
120 compression curb stop (each)	3/4"	_____	_____
TOTAL PRICE DOLLARS			_____