

ELMIRA WATER BOARD

Elmira, New York

Bids on estimated 2010 requirements for:

HYDROFLUOSILICIC ACID

will be received by the Elmira Water Board at it's office at 261 West Water Street, Elmira, New York until 10:00 A.M. on Wednesday, December 09, 2009, and at that time will be publicly opened and read.

The amounts below are estimates only and the quantities actually ordered will be needed to meet demands during 2010.

Bids must be in sealed envelopes and the quoted material designated on the outside of the envelope. Standard Non-Collusive Bidding Certificate, Waiver of Immunity and Certification of Bidder regarding Equal Employment Opportunity must be signed and submitted with the bid.

The Board reserves the right to reject any or all bids and to re-advertise for new bids at it's discretion.

<u>Amount</u>	-	Approximately 12, 000 Gallons/Year
<u>Standard</u>	-	AWWA B703-89 NSF Certification.
<u>Bid Amount</u>	-	Price should be quoted in price per gallon delivered and should <u>include</u> any other charges (freight and shipping, Superfund, insurance surcharge, etc.) associated with the purchase of this product.
<u>Delivery</u>	-	To be delivered upon order in <u>1,000</u> gallon shipments to the Filtration Plant, 1 Fountain Drive, Elmira, New York between the hours of 7 A.M. to 3 P.M. Each delivery to include the certificate of analysis for that lot and an NSF certification on the MSDS.
<u>Invoicing</u>	-	Invoices <u>must</u> be in the same unit of measurement as quoted on bid sheet. Specification compliance must be shown on purchase order contract.
<u>Specification Compliance</u>	-	The percent of Hydrofluoric Acid (% HF) must not reach or exceed 1%.