

ELMIRA WATER BOARD

Elmira, New York

Bids on estimated 2010 requirements for:

LIQUID ORTHOPHOSPHATE

will be received by the Elmira Water Board at its office at 261 West Water Street, Elmira, New York until 10:00 A.M. on Wednesday, December 09, 2009, and at that time will be publicly opened and read.

The amounts below are estimates only and the quantities actually ordered will be needed to meet demands during 2010. The product shall be "Carus 4500" or an equivalent product.

Bids must be in sealed envelopes and the quoted material designated on the outside of the envelope. Standard Non-Collusive Bidding Certificate, Waiver of Immunity and Certification of Bidder regarding Equal Employment Opportunity must be signed and submitted with the bid.

The Board reserves the right to reject any or all bids and to re-advertise for new bids at its discretion.

Amount Yearly use may be up to 8,000 gallons

Standard Physical Description: Clear, colorless liquid with no foreign odor

Typical Specifications:

Maximum Use Level	31.0 mg/l
Specific Gravity @ 25°C	1.32 +/- 0.03
Sodium Phosphate Content	28%
Lbs Per Gallon:	10.7 - 11.3
pH	3.8 +/- 0.5

Certifications: Certified by NSF to conform to ANSI/NSF Standard 60.

Packaging - Material is to be delivered in tanker truck loads of 3,800/4,000 gallons

Bid Amount - Unit price should be quoted in price per gallon and include any other charges (Superfund, insurance, shipping, surcharge, etc.) associated with the purchase of this product.

Delivery - In truck load lots as ordered and delivered to the Filtration Plant, 1 Fountain Drive, Elmira, New York between the hours of 7 A.M. to 3 P.M. **Each delivery will include the lot sample and certificate of analysis for that lot.**

Invoicing - Invoices must be in the same unit of measurement as quoted on bid sheet.