

## ELMIRA WATER BOARD

Elmira, New York

Bids on estimated 2012 requirements for:

### Liquid Sodium Permanganate

will be received by the Elmira Water Board at it's office at 261 West Water Street, Elmira, New York until 10:00 A.M. on Wednesday, December 07, 2011, and at that time will be publicly opened and read.

The amounts below are estimates only and the quantities actually ordered will be needed to meet demands during 2012.

Bids must be in sealed envelopes and the quoted material designated on the outside of the envelope. Standard Non-Collusive Bidding Certificate, Waiver of Immunity and Certification of Bidder regarding Equal Employment Opportunity must be signed and submitted with the bid.

The Board reserves the right to reject any or all bids and to re-advertise for new bids at it's discretion.

- Amount - Approximately 3 - 330 gallon bulk deliveries of 15% Liquid Sodium Permanganate.
- Standard - AWWA B603-2003 NSF Certification  
Liquid Sodium Permanganate supplied according to the provisions of this standard shall contain approximately 15 percent Sodium Permanganate (KaMnO4). Final acceptance of the bid is contingent upon the provider receiving approval from the Chemung County Health Department for use of the providers product.
- Bid Amount - Price should be quoted unit price per 330 gallon bulk delivered and should include any other charges (freight and shipping, Superfund, insurance surcharge, etc.) associated with the purchase of this product.
- Delivery - Liquid Sodium Permanganate shall be shipped in 330 gallon bulk containers as ordered to the Filtration Plant, 1 Fountain Drive, Elmira, New York between the hours of 7 AM to 3 PM. Each delivery to include the certificate of analysis for that lot and an NSF certification on the MSDS. **Each delivery will include the lot sample and certificate of analysis for that lot.**
- Invoicing - Invoices must be in the same unit of measurement as quoted on bid sheet. Specification compliance must be shown on purchase order contract.
- Specification Compliance - Sodium Permanganate (as KaMnO4) as a percentage shall be between 14.0 minimum to 15.5 maximum.