

**ELMIRA WATER BOARD**  
 Elmira, New York  
 Bids for Estimated 2012 Requirements for:

**SPECIFICATIONS**  
**TYTON JOINT DUCTILE IRON PIPE**

will be received by the Elmira Water Board at its office at 261 West Water Street, Elmira, New York 14901 until 10:00 A.M. on Wednesday, December 07, 2011. At this time the bids will be publicly opened and read.

The pipe joint fittings shall be push-on joints and the pipe shall be centrifugally cast ductile iron pipe conforming with ANSI A 21.51-1986 Class 52 pipe complete with accessories. Pipe shall be double cement lined with paint seal coat and tar coated on the outside in accordance with ANSI specifications A 21.4-1990. Push-on joint rubber gaskets and joint lubricant shall conform with ANSI specifications A 21.11-1990.

Bids shall be quoted on the below quotation form. Bid price should include freight delivered to the Elmira Water Board's Maintenance Shop yard at 760 Bonview Street, Elmira, New York.

Bids must be in sealed envelopes and the quoted material designated on the outside of the envelope. Standard Non-Collusive Bidding Certificate, Waiver of Immunity and Certification of Bidder regarding Equal Employment Opportunity must be signed and submitted with the bid.

The Elmira Water Board reserves the right to waive any informalities and to reject any or all bids and to re-advertise for new bids at its discretion.

BIDDER NAME: \_\_\_\_\_

Phone: \_\_\_\_\_ Fax: \_\_\_\_\_

Email: \_\_\_\_\_

**QUOTATION FORM**

<u># OF UNITS</u>	<u>SIZE</u>	<u>COST/UNIT</u>	<u>EXTENDED TOTAL</u>
500'	4"	_____	_____
4,000'	6"	_____	_____
1,000'	8"	_____	_____
1,000'	10"	_____	_____
200'	12"	_____	_____
60'	16"	_____	_____
TOTAL PRICE DOLLARS			_____